1/18/2018 Product Details



Product 20731

Number:

Order FPC40/830

Abbreviation:

General 40W, T5 Pentron Circline fluorescent lamp, 3000K color temperature, rare earth

Description: phosphor, 82 CRI

Product Information

Abbrev. With Packaging Info. FPC40830 12/CS 1/SKU Actual Length (in) 12.008 Actual Length (mm) 305.00 Average Rated Life (hr) 12000 2GX13 Base Bulb T5 Color Temperature/CCT (K) 3000 0.630 Diameter (in) 16.00 Diameter (mm) Family Brand Name Pentron® 3400 Initial Lumens at 25C 2815 Mean Lumens at 25C Nominal Length (in) 12.008 305.00 Nominal Length (mm) Nominal Wattage (W) 40.00 Outside Diameter (in) 11.54 - 12.01 293-305 Outside Diameter (mm)



Footnotes

- Approximate initial lumens after 100 hours operation.
- The life ratings of fluorescent lamps are based on 3 hr. operating cycles under specified conditions and with ballast meeting ANSI specifications. If operating cycle is increased, there will be a corresponding increase in the average hours life.
- Lumen output and life rated on high frequency operation.
- Minimum starting temperature is a function of the ballast; consult the ballast manufacturer.
- There is a NEMA supported, industry issue where T2, T4, and T5 fluorescent and compact fluorescent lamps operated on high frequency ballasts may experience an abnormal end-of-life phenomenon. This end-of-life phenomenon can resultin one or both of the following: 1. Bulb wall cracking near the lamp base. 2. The lamp can overheat in the base area and possibly melt the base and socket. NEMA recommends that high frequency compact fluorescent ballasts have an end-of-life shutdown circuit which will safely and reliably shut down the system in the rare event of an abnormal end-of-life failure mode described above. The final requirements of this system are yet to be defined by ANSI. For additional information refer to NEMA papers on their WEBSITE at www.NEMA.org.
- Mean lumens are measured at 40% of average rated lamp life.
- The distance between any parts of the lamp and any conductive surface of the luminaire should not be less than 3 mm (applies to all high frequency ballasted systems).
- The lamp should not be in contact with any surface of the luminaire (applies to either high frequency or 60Hz ballasted systems).